



[Knowledgebase](#) > [MFR300](#) > [Voltage Asymmetry calculation - MFR300 - MFR13](#)

## Voltage Asymmetry calculation - MFR300 - MFR13

Simon - 2021-12-15 - [MFR300](#)

- MFR13
  - The MFR13 calculates the asymmetry as the maximum deviation of each delta voltage from the average.
  - In Principle it is the ANSI standard, but
    - ANSI: monitor MAX / Average in [%]
    - MFR13: monitor MAX-Average in [V]

MFR300

The MFR300 calculates the asymmetry from the negative sequence in relation to the nominal voltage

The formula of the negative sequence is:



The monitoring would be for  $|G|$  / **nominal voltage**