



[ナレッジベース](#) > [easYgen-3000XT](#) > [easYgen-3000XT J1939 protocol supporting Axiomatic J1939 analog scanners](#)

easYgen-3000XT J1939 protocol supporting Axiomatic J1939 analog scanners

Clemens - 2024-09-27 - [easYgen-3000XT](#)

Third party J1939 analog input collectors like from e.g. www.axiomatic.com can be connected to easYgen-3000XT CAN interface to increase numbers of external analog inputs e.g. [Pt100](#), [Thermocouples](#),...).

Attached PDF is showing long list of supported J1939 (SPN (Suspect parameter Number)& PGN (Parameter Group Number)) messages

[easYgen-3000XT-Series-1939-Protocol.pdf](#)

The collected J1939 messages can then re-used in easYgen's logics& analog manager

