



[ナレッジベース](#) > [MFR300](#) > [I cannot change Toolkit MFR300 Parameters in MFR300 kW transducer](#)

## **I cannot change Toolkit MFR300 Parameters in MFR300 kW transducer**

Clemens - 2023-01-20 - [MFR300](#)

Go for Code Level 5

Code is **0 5 0 0**

That shall unlock the locked parameters you cannot access by Level 3..