



[Knowledgebase](#) > [Power Management](#) > [easYgen-3000XT](#) > [easYgen-3000XT PWM settings for CAT ADEM interfacing](#)

easYgen-3000XT PWM settings for CAT ADEM interfacing

Justin Schneider - 2026-07-27 - [easYgen-3000XT](#)

easYgen's PWM PID output signal need to set to min 50% and max 85% (parameter 5208 and 5209) when a CAT ADEM ECM is connected.

