



[Knowledgebase](#) > [Power Management](#) > [easYgen-3000XT](#) > [application](#) > [How to handle the aftertreatment of exhaust gas for stage V engines via J1939?](#)

How to handle the aftertreatment of exhaust gas for stage V engines via J1939?

Justin Schneider - 2026-07-27 - [application](#)

analog values

the following additional values get visualized:



Please use the AnalogManager for other use-cases (eg. control via 'flexible limits')

Status visualizations:



commands:

„Inhibit regeneration “ SPN 3695

„Force regeneration “ SPN 3696



The standard J1939 messages are supported plus some manufacturer specific values. Example OEMs with custom stage V messages are Scania or Volvo

*(*more upon request. If you need further OEM specific SPNs in the J1939 communication - please contact us!)*