



[Knowledgebase](#) > [Power Management](#) > [easYgen-3000XT](#) > [communication](#) > [Mssing member {4063} LS5 V2 not recognizing](#)

Mssing member {4063} LS5 V2 not recognizing

Justin Schneider - 2026-07-27 - [communication](#)

What you can check is...

- Is the monitoring activated in all LS units?

4060	Monitoring	2	On	Multi-unit missing members monitoring is carried out.
			[Off]	Monitoring is disabled.
				Notes This parameter only applies to application mode A02 .

- Is the number of LS5 communicating configured correctly in all units?

4060	Monitoring	2	On	Multi-unit missing members monitoring is carried out.
			[Off]	Monitoring is disabled.
				Notes This parameter only applies to application mode A02 .

- How many units are shown in the multi unit screen?