

<u>Knowledgebase</u> > <u>Electronic Controls</u> > <u>Factory settings files for 2301E</u>

Factory settings files for 2301E

John Tranoudis - 2024-09-30 - Electronic Controls

These are the default (factory) settings files for 2301E Engine controllers from Rev NEW to G.

To upload any of these files you will need to have the latest Toolkit Tool, a serial cable (RS-232) and a null modem. In case the serial cable is crossed, null modem is not required.

- Tags
- <u>2301E</u>

Attachments

• Default Settings files.zip (327.43 KB)