



[ナレッジベース](#) > [Power Management](#) > [GCP-3x](#) > [Order code of old obsolete GCP-3x Packages](#)

Order code of old obsolete GCP-3x Packages

Justin Schneider - 2026-07-27 - [GCP-3x](#)

GCP-3XYZ B- ABC-SCxx

X = 1 = Generator Circuit breaker
breaker

X= 2 = Generator and Mains breaker

X = 0 = no

Y = 1 = 100 VAC voltage sensing

Y = 4 = 400 VAC voltage sensing

Z = 1 = ../1A current sensing

Z =5 =../5A current sensing

B = flush mounting

There where different packages (ABC)

BPQ Base Package with 2 analog PIDs for speed &voltage adjustment (raise&lower via Logik Manager)

BPD Base Package with 2 pot free digital outputs for speed &voltage adjustment

XPQ Medium Package with 2 analog outputs for speed &voltage adjustment

XPD Medium Package with 2 pot free digital outputs for speed &voltage adjustment

XPQ-Scxx enhanced Package with 2 pot free analog outputs for speed &voltage adjustment and 2nd CANbus for ECU communication and IKD1M support

XPD-Scxx enhanced Package with 2 pot free digital outputs for speed &voltage adjustment and 2nd CANbus for ECU communication and IKD1M support

RPQ was a special rental version based on XPQ-Scxx package