



[ナレッジベース](#) > [Power Management](#) > [MFR300](#) > [Suzlon MFR13 P/N 8441-1120 MFR1371M/DQ3RSU08UV replacement MFR300-71M/SU08 P/N 8444-1115 for windmill applications](#)

Suzlon MFR13 P/N 8441-1120 MFR1371M/DQ3RSU08UV replacement MFR300-71M/SU08 P/N 8444-1115 for windmill applications

Justin Schneider - 2026-07-27 - [MFR300](#)

SUZLON - P/N: 51025002 is Woodward's P/N 8441-1120 was a customized multifunctional relay called MFR1371M/DQRSU08UV mainly used on 2MW+ wind mills. This MFR13 is connected via CAN bus to the upper level PLC.

This device has a special customized CAN protocol with option Su08.
P/N 8444-1115 MFR300-71M/SU08 comes with a compatible CAN protocol.

So MFR13 can get replaced by this MFR300, thus you can make sure to maintain the upper PLC.

You can use the same configuration cable P/N 5417-557 DPC-1 or the latest P/N 5417-1251 DPC-USB can be used.

Mains differences :

MFR13



Dimensions: 96 x 72 x 130 mm

690 VAC voltage sensing

../1A current sensing

Accuracy Class 1

MFR13M was with 8923-1023 DIN-rail brackets back panel mounted back panel mounted (DIN-rail mount)

LeoPC configuration software

2 line numeric display

1 x Discrete Input

8 x Discrete Output

only U, f, Df/Dt, monitoring

CAN bus Su08

MFR300



146x128x50 mm

690 VAC voltage sensing

../1A current sensing

Class 0.5

back panel mounted (DIN-rail mount)

Woodward Toolkit software

no display

no Discrete Input

5 x Discrete Output

additional LVRT monitoring

Can bus Su08

All MFR300 documentation can be downloaded here:

https://wss.woodward.com/manuals/PGC/MFR-x00_series/MFR-300

Toolkit Software:

https://wss.woodward.com/manuals/PGC/SW_Tools/ToolKit

Required configuration files:

https://wss.woodward.com/manuals/PGC/MFR-x00_series/MFR-300/02_Config_Files_